

# Attestation of Conformity

No. N8AUK 113943 0003 Rev. 00

**Holder of Certificate:** **HSA ENERJI A.S.**  
OSB III. Kisim Keciliköy OSB Mah.  
Mustafa Kemal Bulvari No:15  
45030 Yunusemre - Manisa  
TÜRKIYE

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulations and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704062232701-00

**Date,** 2022-06-13



( David Bo )

# Attestation of Conformity

No. N8AUK 113943 0003 Rev. 00

## Model(s):

HSA72M10MF-xxxW, xxx = 530 to 545 in steps of 5  
 HSA66M10MF-xxxW, xxx = 485 to 500 in steps of 5  
 HSA60M10MF-xxxW, xxx = 445 to 455 in steps of 5  
 HSA54M10MF-xxxW, xxx = 400 to 410 in steps of 5  
 xxx is standing for rated output power at STC

## Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd No.8 Lanxiang Road Wujin Economic Development Zone Changzhou, Jiangsu, China.
Construction:	Framed, with Junction box, cable and connectors.
Fire Safety Class:	Class C according to UL790

## Tested according to:

EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06